



January 4, 2024

Via Email: rm157@sasktel.net

Hamlet of Edgeley c/o RM of South Qu'Appelle
Box 66
QU'APPELLE SK S0G 4A0

Attention Waterworks Owner/Operator:

RE: Precautionary Drinking Water Advisory for the Hamlet of Edgeley c/o RM of South Qu'Appelle: - Rescinded

The Water Security Agency (WSA) is satisfied with *two sets of* negative bacteriological sampling and adequate disinfection residuals and turbidity values from samples that have been collected from the water distribution system following Powerfailure causing the system depressurization. Therefore, effective immediately the WSA is rescinding the "**Precautionary Drinking Water Advisory**" for the residents and users of the *Hamlet of Edgeley c/o RM of South Qu'Appelle* water supply.

For further information, please do not hesitate to contact the undersigned at 306-533-2136 or brendan.liggett@wsask.ca.

Sincerely,

Brendan Liggett

Brendan Liggett PTech
Environment Officer
Water Security Agency

cc: Derrick Hoehn, Don Turner, Water Advisories – Water Security Agency
Saskatchewan Health Authority, Weyburn Office